

Deep Creek Lake Laboratory
 762 Mayhew Inn Road
 Oakland, Md 21550



Laboratory Director: Dale A. Baker
 Telephone: (301) 387-6162
 Fax: (301) 387-9814
 E-Mail: dbaker@garrettcountry.org

Report of Analysis

Report No: 81280
 Report To: Kitzmiller Water PWSID 011-0013
 Contact:
 Sample ID: Drinking Water
 Description: Kitzmiller Water Complaint
 Kitzmiller WWTP - Hot Water Tank

Date Sampled: 3/20/2024
 Time Sampled: 10:15 AM
 Sampled by: Roger Lapp
 Sampler ID: 8293RL
 Date Received: 3/20/2024
 Time Received: 10:15 AM
 Received Temp: 14°C
 Field Chlorine: N/A

Parameter	Result	Units	RDL	Method	Date / Time Analyzed	By
Selenium	ND	mg/L	0.001	EPA 200.8	3/27/2024 6:07 PM	Contract
Hardness	4.70	mg/L as CaCO3	1.00	Calculation	3/27/2024 6:07 PM	Contract
Copper	1.01	ug/L	1.00	EPA 200.8	3/27/2024 6:07 PM	Contract
Lead	ND	ug/L	0.001	EPA 200.8	3/27/2024 6:07 PM	Contract
Zinc	ND	mg/L	0.002	EPA 200.8	3/27/2024 6:07 PM	Contract
Cadmium	ND	mg/L	0.001	EPA 200.8	3/27/2024 6:07 PM	Contract
Manganese	0.00355	mg/L	0.001	EPA 200.8	3/27/2024 6:07 PM	Contract
Mercury	ND	ug/L	0.100	EPA 200.8	3/27/2024 6:07 PM	Contract
Nickel	ND	mg/L	0.001	EPA 200.8	3/27/2024 6:07 PM	Contract
Arsenic	ND	ug/L	1.0	EPA 200.8	3/27/2024 6:07 PM	Contract
Iron	ND	mg/L	0.050	EPA 200.8	3/27/2024 6:07 PM	Contract
Molybdenum	ND	mg/L	0.001	EPA 200.8	3/27/2024 6:07 PM	Contract

Report of Analysis

Report No: 81280
Report To: Kitzmiller Water PWSID 011-0013
Contact:
Sample ID: Drinking Water
Description: Kitzmiller Water Complaint
Kitzmiller WWTP - Hot Water Tank

Date Sampled: 3/20/2024
Time Sampled: 10:15 AM
Sampled by: Roger Lapp
Sampler ID: 8293RL
Date Received: 3/20/2024
Time Received: 10:15 AM
Received Temp: 14°C
Field Chlorine: N/A

Parameter	Result	Units	RDL	Method	Date / Time Analyzed	By
Chloride - EPA Method	16.5	mg/L	0.500	EPA 300.0	3/27/2024 2:13 AM	Contract
Sulfide	ND	mg/L	0.100	SM 4500-S2 D-2000	3/27/2024 6:58 PM	Contract
Fluoride	0.294	mg/L	0.005	EPA 300.0	3/27/2024 2:15 AM	Contract
Antimony	ND	mg/L	0.001	EPA 200.8	3/27/2024 6:07 PM	Contract
Barium	0.0706	mg/L	0.010	EPA 200.8	3/27/2024 6:07 PM	Contract
Beryllium	ND	mg/L	0.001	EPA 200.8	3/27/2024 6:07 PM	Contract
Thallium	ND	mg/L	0.001	EPA 200.8	3/27/2024 6:07 PM	Contract
Nitrate / Nitrite	ND	mg/L	0.500	EPA 300.0	3/27/2024 2:15 AM	Contract
Silver	ND	mg/L	0.001	EPA 200.8	3/27/2024 6:07 PM	Contract
Sulfate	3.5	mg/L	0.3	EPA 300.0	3/27/2024 2:15 AM	Contract
Chromium	ND	mg/L	0.001	EPA 200.8	3/27/2024 6:07 PM	Contract

Notes / Parameter Qualifiers:

Standard Acronyms/Flags

ND Not Detected
MDL Method Detection Level
RDL Reporting Detection Level

Reviewed and approved by:



Report Date: 4/1/2024