

Deep Creek Lake Laboratory
762 Mayhew Inn Road
Oakland, Md 21550

Laboratory Director: Dale A. Baker
Telephone: (301) 387-6162
Fax: (301) 387-9814
E-Mail: dbaker@garrettcounty.org



Report of Analysis

Report No:	82453	Date Sampled:	7/24/2024
Report To:	Kitzmilller Water PWSID 011-0013	Time Sampled:	11:30 AM
Contact:		Sampled by:	Dale Baker
Sample ID:	Raw	Sampler ID:	1102DB
Description:	Kitzmilller Raw Water Complaint Investigation	Date Received:	7/24/2024
		Time Received:	1:00 PM
		Received Temp:	2°C
		Field Chlorine:	N/A

Parameter	Result	Units	RDL	Method	Date / Time Analyzed	By
Sulfate	4.16	mg/L	0.250	EPA 300.0	7/26/2024 8:18 PM	Contract
Fluoride	0.444	mg/L	0.005	EPA 300.0	7/26/2024 8:18 PM	Contract
Sulfide	0.720	mg/L	0.100	SM 4500-S2 D-2000	7/30/2024 5:16 PM	Contract
Manganese	0.00849	mg/L	0.001	EPA 200.8	8/1/2024 2:10 PM	Contract
Hardness	5.95	mg/L as CaCO ₃	1.00	SM2340B	8/1/2024 2:10 PM	Contract
Iron	ND	mg/L	0.050	EPA 200.8	8/1/2024 2:10 PM	Contract
pH	8.61	STD		EPA150.1	7/24/2024 11:30 AM	DB

Notes / Parameter Qualifiers:

Standard Acronyms/Flags

ND Not Detected
MDL Method Detection Level
RDL Reporting Detection Level

Reviewed and approved by:

A handwritten signature in black ink that reads "Dale Baker".

Report Date: 8/5/2024